




GENERAL NOTES:-

- 1-ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE INDICATED.
- 2-POWER CIRCUITS SHALL BE INSIDE PVC CONDUIT TYPE Ø25mm UNLESS OTHERWISE INDICATED
- 3-CONDUIT RUN SHALL NOT HAVE MORE THAN TWO (2) 90° BENDS IN ANY ONE RUN AND PULL BOXES SHALL BE PROVIDED WHERE NECESSARY.
- 4-ALL POWER DISTRIBUTION AND POWER PANELBOARDS ARE TO BE INSTALLED WITH TOP ENDS AT 1800mm ABOVE F.F.L. UNLESS OTHERWISE INDICATED.
- 5-ELECTRICAL WATER HEATER OUTLEARE TO BE INSTALLED A/2200mm ABOVE F.F.L.
- 6-EXACT SIZING OF CABLE TRAYS IS THE CONTRACTOR RESPONSIBILITY AND MUST BE ACCORDING TO FINAL SIZES OF ACCEPTED CABLES AND COMPLY WITH SPECS

LEGEND	
SYMBOL	DESCRIPTION
	POWER SOCKET DOUBLE GANG
	MDP
	AC SWITCH
	LIGHTING SOCKET
	W.P. Water Proof Socket



ABBASIA HOSPITAL
ELECTRICAL

DESIGNER'S SEAL & SIGNATURE

DATE : September 2021

A/E :

APPROVED DATE

WFP :

APPROVED DATE

1 Light Current
1 Revision

APPROVED

date

CODE : 1100
SCALE : 1:100
CONTRN

SHEET 1 OF 1