## **Specifications**

	Non-residential area
Location	Not adjacent or within a proximity to governmental security forces or checkpoints
	Not adjacent to governmental institutions
	Not adjacent to fuel stations
	Close or within proximity to public transportation staging points
	Police and LRC should by reachable within 10 minutes
	Should be accessible from at least two different directions
	Should be away from the highway
Lease period	Initial 3 years with possibility of 2 additional years extensions
	Building : 3,000sqm with minimum of 2,000 sqm as office space
Space availability	to include :
	Basement floors
	Ground floor
	Upper floors
	o Common areas
	○ Storage Area
	Amenities areas, technical rooms
	<ul> <li>Fire escape stairs</li> </ul>
	o Indoor/outdoorparkingspots (minimum 18 indoor parking spots)
	<ul> <li>Building parameters</li> </ul>
	<ul> <li>Outdoor areas</li> </ul>
Age of building	The building should be 1 to 10 years old.
Age of building	Preferably with recent renovation if old, renovation that covers civil, electrical and mechanical works.
	Ready for immediate occupancy.
State of building	The building should be designed as office space and not a residential to be changed into offices.
	The building should be equipped with a complete infrastructural network at all levels and at common areas.
	Building structural earthquake assessment (Seismic study)
	The network should at least include the electrical, sewage, water and mechanical systems fully operational and connected to
	the outer infrastructural sources.
Perimeter fence for the	Preferably with a reinforced concrete wall (minimum height of 2.8m) or with block wall all around the building with vehicular
building	and pedestrian accesses.
Electrical supply for the	The building or land electrical network must be legally connected to the EDL.
building	To consider a minimum space area for 3 (three) generators is about 90 sqm and 3 Diesel Tanks
	The tap water network must be legally connected to the public infrastructural source.
Water supply for the building	A minimum reservoir tank of 2000 liters per floor should be available or one big reservoir tank with the same floors capacity
	connected to all pushed by pumps.
. "	The building should have reasonable space around it with at least 4 meters "set-back" at all sides from neighboring buildings
Surrounding	and some stand off distance from the road - between 10 to 15 meters.
	As per rules & regulations, each floor area must have its respective number of parking spots inside the building premises, either
Parking	at the indoor area or at the outdoor area.
Legal Documents for both	Ownership certificate must be valid and available.
building and land	Related government fees should be duly settled.
Server Room	Raised floor system, Camera Surveillance, 2x Central UPs with batteries for extended autonomy
	Seperated power supply from all other systems, Adequate fire extinguisher for IT equipments, smoke detector,
	managed access control, no windows, protection from Heat, flame and water. 3 x ACs
Roof top	Roof top without obstructions for VSAT installation and Starlink terminal, Telecom Antenna for VHF,
	Microwave Antenna for Internet, Lightining Rod and Serge Protection (Earthing)
Ogero	Fiber connection and Ogero junction box for 50 x Landlines
LAN	Cat6 Network Cables (3M/Belden or equivalent) -User outlets/point includes: 3 x UPS (UK) + 1 x EDL (EU)
	+ 2 x Data ports
	Wifi AP (cabling) to cover all floors from corner to corner.
	Secure LAN cabinet location on each floor with secure access
Printer outlets	1 x Data port + 1 x UPS (UK) + 2 x EDL (EU)