

RESPONSE TO BIDDER QUERIES

FOR INVITATION TO BID: ITB-018-2022 SUPPLY, DELIVERY, AND INSTALLATION OF PREFABRICATED CONTAINERS

Question 1: Could you kindly advise about the concrete block/floor height that the containers will be placed on it? It is needed to determine the dimensions of the requested ladder and ramp

Answer 1: Locations shall be visited prior to the manufacturing process together with the contractor. Ladder and ramp measurements can be done during the visits.

Question 2: It is stated that there will be no separation wall / internal wall inside of the container however, in Annex A/item 3, the internal wall is specified. We assume that the sandwich panels are requested as an external wall cladding material. Could you kindly confirm/advise?

Answer 2: These are empty containers without partitions or interior walls.

Question 3: In Annex A/item 2, the container's external height is specified as 2.70m but under item 17, the external height is shown as 2.60m on the layout. Which one should be taken as a reference? Please advise.

Answer 3: External height is specified as 2.70m.

Question 4: Under section 1 REQUIREMENTS, it is specified that the " other UN Agencies shall be entitled to the same prices of the successful bidders ... "Could you kindly give more detail about that? Do you request us to give validity to the price even if the project location is abroad?

Answer 4: Other UN Agencies shall be entitled to the same prices and terms as those contained in the offer. Delivery terms specified in the tender are within Turkiye.

Question 5: We are aware that the exact addresses will be shared with the winning company, but still would it be possible to name the cities at least?

Answer 5: The exact address location will be visible for the awarded company at a later stage.

Question 6: UNHCR Logo and/or partner logo is required to be painted on the containers. Would you please provide soft copies of those logos including the dimensions and details required?

Answer 6: Please refer to Annex-A Packaging/Visibility number 15. A soft copy of the logo shall be provided to the winning company.
